



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 07/22/2016
Received: 07/13/2016
Sampled By: Ron Wanner
Work Order: 6195056

**C
L
I
E
N
T**
Jewell School District #8
Attn: Michael Hinson
83874 Hwy 103
Seaside OR, 97138
Phone: (503) 755-2451

Project: Lead and Copper
Project # : N/A
PWSID # : 41-90531

Sampling Location: Jewell School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6195056-01	Sample Name: #1 Girls Locker Rm Sampled: 7/11/16 17:04						Matrix: Water
	+Copper	1055	SM3111B	0.904	mg/L	0.050	07/20/16 17:13
	+Lead	1030	EPA 200.9	ND	ppb	2.0	07/20/16 16:58
6195056-02	Sample Name: #2 Boys Locker Rm Sampled: 7/11/16 17:05						Matrix: Water
	+Copper	1055	SM3111B	0.409	mg/L	0.050	07/20/16 17:13
	+Lead	1030	EPA 200.9	ND	ppb	2.0	07/20/16 16:58
6195056-03	Sample Name: #3 Office Sampled: 7/11/16 17:09						Matrix: Water
	+Copper	1055	SM3111B	0.298	mg/L	0.050	07/20/16 17:13
	+Lead	1030	EPA 200.9	2.1	ppb	2.0	07/20/16 16:58
6195056-04	Sample Name: #4 High School Sampled: 7/11/16 17:10						Matrix: Water
	+Copper	1055	SM3111B	0.320	mg/L	0.050	07/20/16 17:13
	+Lead	1030	EPA 200.9	3.7	ppb	2.0	07/20/16 16:58
6195056-05	Sample Name: #5 Cafeteria Sampled: 7/11/16 17:13						Matrix: Water
	+Copper	1055	SM3111B	0.234	mg/L	0.050	07/20/16 17:13
	+Lead	1030	EPA 200.9	ND	ppb	2.0	07/20/16 16:58

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.